

GENESYS

This PDF is generated from authoritative online content, and is provided for convenience only. This PDF cannot be used for legal purposes. For authoritative understanding of what is and is not supported, always use the online content. To copy code samples, always use the online content.

Genesys Administrator Extension Deployment Guide

Configuring the Auditing Feature

Configuring the Auditing Feature

Contents

- 1 Configuring the Auditing Feature
 - 1.1 GAX Application
 - 1.2 Message Server
 - 1.3 Database Configuration

To enable the Auditing feature, you must configure GAX, Message Server, and the database. GAX must have a connection to Message Server.

GAX Application

Enable Auditing by setting the value of the auditing option in the general section of the GAX Server application to true.

Next, in the general section of the GAX application, make the following configuration option settings:

- Set the number of switch-over attempts before GAX tries to switch-over to the redundant node to 1. To do this, set the value of the max_switchovers option in the general section of the GAX application to 1. A value of 0 means switch-overs are disabled. Negative values allow an unlimited numbers of switch-overs, and, therefore, a continuous reconnect process if the server is unreachable. Setting a negative value is recommended for production systems.
- Set the number of connection attempts before GAX tries to switch over to the redundant node. To do this, set the value of the attempts option in the general section of the GAX application to 1.
- Set the timeout interval between connection attempts to Message Server. To do this, set the value of the warmstandby timeout option in the general section of the GAX application to any positive integer.
- Set the protocol timeout, which is the time in seconds after which GAX gives up attempting to connect. To do this, set the value of the timeout option in the general section of the GAX application to 30.

Message Server

In the Message Server object, set the db storage option in the messages section to the value true.

If the db_storage option is not set to true, Message Server does not save the Audit data to its database.

Database Configuration

To read the Audit data from the Log DB, a DAP must be configured and connected to the GAX Server Application object. Configure the DAP in the same way that DAPs were configured for the GAX database and License Usage Reporting. To identify the DAP role, set the value of the role option in the GAX section of the DAP to auditing.